



CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2001689R1

Socket-outlet

Type designation:

***-67835, ***-67845, ***-67865

Certificate holder:

NIKO N.V.
Industriepark West 40
9100 St Niklaas, Belgium

The product complies with the standard(s):

IEC 60884-1:2002+A1+A2
SS 428 08 34:2013+T1

Date of expiry:

10 June, 2025

Intertek

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:

Date: 02 December, 2024

Anneli Averland Johansson

APPENDIX:

Reference No. SE-S-2001689R1

Technical Data:

Type designation	***-67835, ***-67845, ***-67865
Rated voltage (V)	250V~
Rated current (A)	16A
IP-Class	20
Standard sheet	III
Trademark	NIKO
Test Report	2012502STO-001, 2250325.50, 2408202STO-001
Product information	Flush type socket-outlet 2P+E. Two-fold with shutters. Screwless terminals.

The socket-outlet may not be installed in a non-earthed metal wall box.

Manufacturing Sites:

NIKO N.V.
Industriepark West 40
9100 St Niklaas, Belgium

The instruction for use shall be written in a language acceptable according to the national regulation in the country where the product is to be used.

The certificate applies for countries that have sanctioned the use of plugs/outlets according to subject standard sheet and component standard.

This certificate is based on CB with ref. No. NL-69261 dated 20 November 2020, issued by Dekra.

This certificate replaces previously issued ref. No. SE-S-2001689 dated 10th June 2020.
A new certificate has been issued on account of the addition of a new type; ***-67865.

Certification Body:

Intertek Semko AB, Product Certification

Place: Kista - Stockholm

Signed:



Date: 02 December, 2024

Anneli Averland Johansson